

Your C.O.C. #: 1027673-01-01

Attention: Jeremy George

GWS Glenbriar Water Store
 Bottled Water
 183 Frobisher Drive
 Waterloo, ON
 CANADA N2V 2G4

Report Date: 2025/02/05

Report #: R8481900

Version: 1 - Final

CERTIFICATE OF ANALYSIS

BUREAU VERITAS JOB #: C511061

Received: 2025/01/30, 08:59

Sample Matrix: Water
 # Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
Alkalinity	1	N/A	2025/02/05	CAM SOP-00448	SM 24 2320 B m
Carbonate, Bicarbonate and Hydroxide	1	N/A	2025/02/05	CAM SOP-00102	APHA 4500-CO ₂ D
Chloride by Automated Colourimetry	1	N/A	2025/02/05	CAM SOP-00463	SM 24 4500-Cl E m
Conductivity	1	N/A	2025/02/05	CAM SOP-00414	SM 24 2510 m
Dissolved Organic Carbon (DOC) (1)	1	N/A	2025/02/04	CAM SOP-00446	SM 24 5310 B m
Hardness (calculated as CaCO ₃)	1	N/A	2025/02/05	CAM SOP 00102/00408/00447	SM 2340 B
Metals Analysis by ICPMS (as received) (2)	1	N/A	2025/02/04	CAM SOP-00447	EPA 6020B m
Ion Balance (% Difference)	1	N/A	2025/02/05		
Anion and Cation Sum	1	N/A	2025/02/05		
Total Ammonia-N	1	N/A	2025/02/05	CAM SOP-00441	USGS I-2522-90 m
Nitrate & Nitrite as Nitrogen in Water (3)	1	N/A	2025/02/04	CAM SOP-00440	SM 24 4500-NO ₃ I/NO ₂ B
pH	1	2025/02/04	2025/02/05	CAM SOP-00413	SM 24th - 4500H+ B
Orthophosphate	1	N/A	2025/02/05	CAM SOP-00461	SM 24 4500-P E
Sat. pH and Langelier Index (@ 20C)	1	N/A	2025/02/05		Auto Calc
Sat. pH and Langelier Index (@ 4C)	1	N/A	2025/02/05		Auto Calc
Sulphate by Automated Turbidimetry	1	N/A	2025/02/05	CAM SOP-00464	SM 24 4500-SO ₄ 2- E m
Total Dissolved Solids (TDS calc)	1	N/A	2025/02/05		Auto Calc

Remarks:

Scope Statement:

The analysis detailed in this document is intended to assist you, the Client, in your efforts and responsibility to produce safe food. The analysis may be for contaminants or adulterants that are known to be or may potentially be harmful, or that may impact on the quality or desired characteristics of the product. The results are representative of the samples at the time and condition of submission, and as determined by the indicated method(s). When Bureau Veritas has not been responsible for the sampling stage (e.g. the sample has been provided by the customer), the results apply to the sample received from the client. Any inference as to their applicability to any particular product, production lot, intermediate, ingredient or facility should be made by an individual with relevant expertise, based on an understanding of the product and the suitability of the sampling protocol. The report shall not be reproduced except in full without approval of the laboratory.

Reference Method suffix "m" indicates test methods incorporate validated modifications from specific reference methods to improve performance.

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) Dissolved Organic Carbon (DOC) present in the sample should be considered as non-purgeable DOC.

(2) Metals analysis was performed on the sample 'as received'.



Your C.O.C. #: 1027673-01-01

Attention: Jeremy George

GWS Glenbriar Water Store
Bottled Water
183 Frobisher Drive
Waterloo, ON
CANADA N2V 2G4

Report Date: 2025/02/05

Report #: R8481900

Version: 1 - Final

CERTIFICATE OF ANALYSIS

BUREAU VERITAS JOB #: C511061

Received: 2025/01/30, 08:59

(3) Values for calculated parameters may not appear to add up due to rounding of raw data and significant figures.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to:

Nazeema Rahaman, Project Manager

Email: Nazeema.Rahaman@bureauveritas.com

Phone# (905)817-5806

=====

This report has been generated and distributed using a secure automated process.

Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rodney Major, General Manager responsible for Ontario Environmental laboratory operations.

Total Cover Pages : 2

Page 2 of 6

Bureau Veritas 6740 Campobello Road, Mississauga, Ontario, L5N 2L8 Tel: (905) 817-5700 Toll-Free: 800-563-6266 Fax: (905) 817-5777 www.bvna.com

Microbiology testing is conducted at 6660 Campobello Rd. Chemistry testing is conducted at 6740 Campobello Rd.



ELEMENTS BY ATOMIC SPECTROSCOPY (WATER)

Bureau Veritas ID				ANSC47	
Sampling Date				2025/01/30 07:30	
COC Number				1027673-01-01	
	UNITS	MAC	A/O	DISTILLED	RDL
Aluminum (Al)	ug/L	-	100	ND	4.9
Antimony (Sb)	ug/L	6	-	ND	0.50
Arsenic (As)	ug/L	10	-	ND	1.0
Barium (Ba)	ug/L	1000	-	ND	2.0
Beryllium (Be)	ug/L	-	-	ND	0.40
Boron (B)	ug/L	5000	-	ND	10
Cadmium (Cd)	ug/L	5	-	ND	0.090
Calcium (Ca)	ug/L	-	-	ND	200
Chromium (Cr)	ug/L	50	-	ND	5.0
Cobalt (Co)	ug/L	-	-	ND	0.50
Copper (Cu)	ug/L	-	1000	42	0.90
Iron (Fe)	ug/L	-	300	ND	100
Lead (Pb)	ug/L	10	-	ND	0.50
Lithium (Li)	ug/L	-	-	ND	5.0
Magnesium (Mg)	ug/L	-	-	ND	50
Manganese (Mn)	ug/L	-	50	ND	2.0
Molybdenum (Mo)	ug/L	-	-	ND	0.50
Nickel (Ni)	ug/L	-	-	ND	1.0
Phosphorus (P)	ug/L	-	-	ND	100
Potassium (K)	ug/L	-	-	ND	200
Selenium (Se)	ug/L	50	-	ND	2.0
Silicon (Si)	ug/L	-	-	ND	50
Silver (Ag)	ug/L	-	-	ND	0.090
Sodium (Na)	ug/L	-	200000	ND	100
Strontium (Sr)	ug/L	-	-	ND	1.0
Thallium (Tl)	ug/L	-	-	ND	0.050
Titanium (Ti)	ug/L	-	-	ND	5.0
Uranium (U)	ug/L	20	-	ND	0.10
Vanadium (V)	ug/L	-	-	ND	0.50
Zinc (Zn)	ug/L	-	5000	ND	5.0
RDL = Reportable Detection Limit MAC,A/O: Ontario Drinking Water Standards - Maximum Acceptable Concentration [MAC] & Table 4-Chemical/Physical Objectives [A/O] - Not Health Related, respectively (Made under the Ontario Safe Drinking Water Act, 2002) ND = Not Detected at a concentration equal or greater than the indicated Detection Limit. N/A = Not Applicable					



RESULTS OF ANALYSES OF WATER

Bureau Veritas ID				ANSC47	
Sampling Date				2025/01/30 07:30	
COC Number				1027673-01-01	
	UNITS	MAC	A/O	DISTILLED	RDL
Anion Sum	me/L	-	-	0.000	N/A
Bicarb. Alkalinity (calc. as CaCO ₃)	mg/L	-	-	ND	1.0
Calculated TDS	mg/L	-	500	ND	1.0
Carb. Alkalinity (calc. as CaCO ₃)	mg/L	-	-	ND	1.0
Cation Sum	me/L	-	-	0.00200	N/A
Hardness (CaCO ₃)	mg/L	-	80:100	ND	1.0
Ion Balance (% Difference)	%	-	-	NC	N/A
Langelier Index (@ 20C)	N/A	-	-	NC	N/A
Langelier Index (@ 4C)	N/A	-	-	NC	N/A
Saturation pH (@ 20C)	N/A	-	-	NC	N/A
Saturation pH (@ 4C)	N/A	-	-	NC	N/A
Ammonia-N	mg/L	-	-	ND	0.050
Conductivity	umho/cm	-	-	1.3	1.0
Organic Carbon	mg/L	-	5	ND	0.40
Orthophosphate (P)	mg/L	-	-	ND	0.010
pH	pH	-	6.5:8.5	5.67	N/A
Sulphate (SO ₄)	mg/L	-	500	ND	1.0
Alkalinity (Total as CaCO ₃)	mg/L	-	30:500	ND	1.0
Chloride (Cl ⁻)	mg/L	-	250	ND	1.0
Nitrite (N)	mg/L	1	-	ND	0.010
Nitrate (N)	mg/L	10	-	ND	0.10
RDL = Reportable Detection Limit MAC,A/O: Ontario Drinking Water Standards - Maximum Acceptable Concentration [MAC] & Table 4-Chemical/Physical Objectives [A/O] - Not Health Related, respectively (Made under the Ontario Safe Drinking Water Act, 2002) ND = Not Detected at a concentration equal or greater than the indicated Detection Limit. N/A = Not Applicable					



GENERAL COMMENTS

Each temperature is the average of up to three cooler temperatures taken at receipt

Package 1	6.7°C
-----------	-------

Results relate only to the items tested.



BUREAU
VERITAS

Bureau Veritas Job #: C511061

Report Date: 2025/02/05

GWS Glenbriar Water Store

Sampler Initials: JG

VALIDATION SIGNATURE PAGE

The analytical data and all QC contained in this report were reviewed and validated by:

Louise Harding, Scientific Specialist

Bureau Veritas has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per ISO/IEC 17025, signing the reports. For Service Group specific validation, please refer to the Validation Signatures page if included, otherwise available by request. For Department specific Analyst/Supervisor validation names, please refer to the Test Summary section if included, otherwise available by request. This report is authorized by Rodney Major, General Manager responsible for Ontario Environmental laboratory operations.